

माधव प्रौद्योगिकी एवं विज्ञान संस्थान, ग्वालियर

MADHAV INSTITUTE OF TECHNOLOGY & SCIENCE, GWALIOR

(Deemed to be University)

NAAC Accredited with A++ Grade

Gola Ka Mandir, Gwalior (M.P.)- 474005, INDIA

Ph.:+91-751-2409300, E-mail: director@mitsgwalior.in, Website: www.mitsgwalior.in

TESTING/CONSULTANCY REPORT

Civil/MKT/AKA/Env. Engg.Lab./ TR No. 339/Hologram No. 767667

To.

The Woodstock School, Kedarpur, Shivpuri Link Road,

Gwalior MP - 474001 Mob.: 9713799241

Email: wookstock_school@yahoo.com

MITS Dispatch

Ref. No. TWS/02/2024/23 Dated 28.02.2024

Site inspection and testing of sealed Water sample for drinking purpose. Sub.

Dear Sir,

Kindly find enclosed herewith the water quality test report of sealed Water sample, safe drinking water and sanitary condition certificate for your Institution.

- Testing and visiting charge of Rs. 9204/- deposited vide UTR NoINDBN14030265859 dated 14.03.2024.
- Sample collected on 16-03-2024.
- Site visit /Testing date on 16-03-2024/19-03-2024.

Report generated on 22.03.2024

(Prof. I/c PHE Lab)

Dr. M.K. Trived (H.C.E.D.)

Dr. Prachi Singh Asst. Prof.

This Testing / Consultancy report is forwarded on the recommendations of the Department Responsibility of Test/Consultancy Report lies with the concerning department.

Consultancy Amount Pale

140302654

name of our Accounts Officer

243124

Mediev Institute of Technology & Science

Gwalfor (M.P.)

THE WOODSTOCK SCHOOL



माधव प्रौद्योगिकी एवं विज्ञान संस्थान, ग्वालियर

MADHAV INSTITUTE OF TECHNOLOGY & SCIENCE, GWALIOR

(Deemed to be University)

NAAC Accredited with A++ Grade

Gola Ka Mandir, Gwalior (M.P.)- 474005, INDIA

Ph.:+91-751-2409300, E-mail: director@mitsgwallor.in, Website: www.mitsgwallor.in

TESTING/CONSULTANCY REPORT

Civil/MKT/AKA/Env. Engg.Lab./ TR No. 339/Ref. Hologram No. 707067 (Pg.C)

Date: 22/3/20 14

The Woodstock School, Kedarpur, Shivpuri Link Road, Gwalior MP - 474001

Mob.: 9713799241

Email: wookstock_school@yahoo.com

MITS Dispatch

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

It is certified that an inspection team headed by Prof. Aditya K. Agarwal, Assistant Professor from Civil Engineering Department, MITS, Gwalior inspected the Woodstock School, Kedarpur, Shivpuri Link Road, Gwalior on 16.03.2024 and on the basis of water test report (attached) bearing No. Civil/MKT/AKA/Env.Engg.Lab./TR No. 339/Ref. Hologram No. To7067(fg.A) dated 22 2 2024 of PHE Lab, Civil Engineering Department, MITS, Gwalior certified that the Woodstock School, Kedarpur, Shivpuri Link Road, Gwalior has safe drinking water facilities for the students and members of staff of the institution. School is maintaining the hygienic sanitation condition in the school building and the campus as per norms prescribed by the Central/State/U.T. Govt.

The above certificate is valid for a period of 01 year (March 2024 to February 2025)

Remarks:

This is as per the physical visit conducted at school on 16/03/2024 and water quality testing conducted at our Institute, the water quality test report for the same is annexed with this certificate.

(Prof. I/c PHE Lab)

Dr. M.K. Trived (H.C.E.D.)

HEAD Civil Engg. Deptt. M.I.T.S. Gwalion

THE WOODSTOCK SCHOOL



माधव प्रौद्योगिकी एवं विज्ञान संस्थान, ग्वालियर

MADHAV INSTITUTE OF TECHNOLOGY & SCIENCE, GWALIOR

(Deemed to be University)

NAAC Accredited with A++ Grade

Gola Ka Mandir, Gwalior (M.P.)- 474005, INDIA

Ph.:+91-751-2409300, E-mail: director@mitsgwallor.in, Website: www.mitsgwallor.in

TESTING/CONSULTANCY REPORT

Civil/MKT/AKA/Env. Engg.Lab./ TR No. 339/Ref. Hologram No. To 7067 (16. 4).

Date: 22/3/2024

To.

The Woodstock School, Kedarpur, Shivpuri Link Road,

Gwalior MP - 474001 Mob.: 9713799241

Email: wookstock_school@yahoo.com

MITS Dispatch

TWS/02/2024/23 Dated 28.02.2024 Testing of sealed Water sample for drinking purpose. Sub.

Dear Sir.

Please find herewith the test report of the sealed water sample collected during on visit 16.03.2024 vide above mentioned reference & subject.

TESTING REPORT

	TESTING REPORT	
S. No.	Parameters/Tests	Laboratory Results
1	Temperature	25.3°C
2	Turbidity	Nil
3	Colour	Absent
4	Odour	Un-objectionable
5	Taste	Un-objectionable
6.	pH Value	7.32
7	Acidity	60 mg/l as CaCO ₃
8	Alkalinity	530 mg/l asCaCO ₃
9	Total Solids	894 mg/l
	Dissolved Solids	888 mg/l
10	Suspended Solids	06 mg/l
11		140 mg/l
12	Chlorides(Cl·) Hardness	350 mg/l asCaCO ₃
13	naturess	L

Remarks:

 The above tested Parameters suggest that water could be used for drinking purposes as there is no alternate source of water available in the school as per standards laid down in IS:10500-

2012.

Asst. Prof.

(Prof. I/c PHE Lab)

Dr. M.K. Trivedi (H.C.E.D.)

This Testing/Consultancy report is forwarded on the recommendations of the Department Responsibility of Test / Consultancy Report lies with the concerning department.

Madinay Institute of Technology & Science

Gwaffor (M.P.)

THE WOODSTOCK SCHOOL